

### Surface mounting enclosure, 3 mounting locations

Powering Business Worldwide\*

Part no. M22-13 Article no. 216538 Catalog No. M22-130

**Delivery programme** 

| Product range              |     | RMQ-Titan (drilling dimensions 22.5 mm)  |
|----------------------------|-----|--|
| Basic function             |     | Accessories  |
| Basic function accessories |     | Surface mounting enclosure   |
| Single unit/Complete unit  |     | Single unit  |
|                            |     | With high-grade steel screws   |
| Number of locations        | Qty | y. 3   |
| Cable entry knockouts      |     |  |
| Cable entry                |     | at bottom: $2 \times M20$<br>at top: $2 \times M20$<br>lateral: $2 \times M20/M25$ (1 x each side) |
| Colour                     |     |  |
|                            |     |  |
| RAL Value                  |     | RAL 7035   |
| Colour                     |     | Enclosure base anthracite  |
| Degree of Protection       |     | IP67, IP69K  |
| Connection to SmartWire-DT |     | no   |

## **Technical data**

#### General

| Ambient temperature |    |           |
|---------------------|----|-----------|
| Open                | °C | -25 - +70 |

# Design verification as per IEC/EN 61439

| Technical data for design verification   |    |  |
|--|----|--|
| Operating ambient temperature min.   | °C | -25  |
| Operating ambient temperature max.   | °C | 70   |
| IEC/EN 61439 design verification   |    |  |
| 10.2 Strength of materials and parts   |    |  |
| 10.2.2 Corrosion resistance  |    | Meets the product standard's requirements.                         |
| 10.2.3.1 Verification of thermal stability of enclosures   |    | Meets the product standard's requirements.                         |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |    | Meets the product standard's requirements.                         |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |    | Meets the product standard's requirements.                         |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |    | Please enquire   |
| 10.2.5 Lifting   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions  |    | Meets the product standard's requirements.                         |
| 10.3 Degree of protection of ASSEMBLIES  |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances   |    | Meets the product standard's requirements.                         |
| 10.5 Protection against electric shock   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections  |    | Is the panel builder's responsibility.                             |
| 10.8 Connections for external conductors   |    | Is the panel builder's responsibility.                             |
| 10.9 Insulation properties   |    |  |
| 10.9.2 Power-frequency electric strength   |    | Is the panel builder's responsibility.                             |

| 10.9.3 Impulse withstand voltage                         | Is the panel builder's responsibility.   |
|--|--|
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility.   |
| 10.10 Temperature rise                                   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

### **Technical data ETIM 6.0**

Low-voltage industrial components (EG000017) / Enclosure for control circuit devices (EC000200)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Housing for command and alarm devices (ecl@ss8.1-27-37-12-05 [AKF023011])

| Number of command positions |    | 3                        |
|-----------------------------|----|--------------------------|
| Construction type housing   |    | Surface mounting housing |
| Material housing            |    | Plastic                  |
| Diameter openings           | mm | 22                       |
| Colour housing cover        |    | Grey                     |
| Degree of protection (IP)   |    | IP67                     |
| Width                       | mm | 153                      |
| Height                      | mm | 80                       |
| Depth                       | mm | 56                       |

## **Approvals**

| IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
|--|
| E29184   |
| NKCR   |
| 012528   |
| 3211-03  |
| UL listed, CSA certified   |
| UL/CSA Type 3R, 4X, 12, 13   |
|  |

## **Dimensions**



## **Additional product information (links)**

IL04716003Z (AWA1160-1746) RMQ-Titan System

IL04716003Z (AWA1160-1746) RMQ-Titan System

ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716003Z2015\_02.pdf