

#### Illuminated selector switch actuator, 2 positions, blue, maintained

Powering Business Worldwide\*

Part no. M22-WRLK-B Article no. 216831 Catalog No. M22-WRLK-BQ

**Delivery programme** 

| Product range  |   | RMQ-Titan (drilling dimensions 22.5 mm)                                    |
|--|---|--|
| Basic function   |   | Illuminated selector switch actuator                                       |
| Single unit/Complete unit  |   | Single unit  |
| Design   |   | With thumb-grip  |
|  |   | maintained   |
| Function:  |   |  |
|  |   | V 60°  |
|  |   | 2 positions  |
| Colour   |   |  |
| Thumb-grip   |   | Blue   |
|  |   |  |
| Degree of Protection   |   | IP66   |
| Front ring   |   | Front ring: titanium   |
| Connection to SmartWire-DT   |   | Yes, with SWD-RMQ connections  |
| Actuator travel and actuation force as per DIN EN 60947-5-1, K.5.4.1 |   |  |
| Minimum force for positive opening                                   | N | 0  |
| Front dimensions   |   | 29,7   |
| Instructions   |   | Stay-put/spring-return function, can be changed with coding parts M22-XC-Y |

### **Technical data**

General

| Standards                   |              |                   | IEC/EN 60947<br>VDE 0660   |
|-----------------------------|--------------|-------------------|--|
| Lifespan, mechanical        | Operations   | x 10 <sup>6</sup> | > 0.1  |
| Operating frequency         | Operations/h |                   | ≦ <sub>2000</sub>  |
| Operating torque            |              | Nm                | ≤ <sub>0.3</sub>   |
| Climatic proofing           |              |                   | Damp heat, constant, to IEC 60068-2-78<br>Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature         |              |                   |  |
| Open                        |              | °C                | -25 - +70  |
| Mounting position           |              |                   | As required  |
| Mechanical shock resistance |              | g                 | 30<br>Shock duration 11 ms<br>Sinusoidal<br>according to IEC 60068-2-27        |

# Design verification as per IEC/EN 61439

| Tanhainal data fau danian wavifination                   |                   |   |   |
|--|-------------------|---|---|
| Technical data for design verification                   |                   |   |   |
| Rated operational current for specified heat dissipation | In                | Α | 0 |
| Heat dissipation per pole, current-dependent             | $P_{vid}$         | W | 0 |
| Equipment heat dissipation, current-dependent            | $P_{\text{vid}}$  | W | 0 |
| Static heat dissipation, non-current-dependent           | $P_{vs}$          | W | 0 |
| Heat dissipation capacity                                | P <sub>diss</sub> | W | 0 |

| ŭ  | -25  |
|----|--|
| °C | 70   |
|    |  |
|    |  |
|    | Meets the product standard's requirements.   |
|    | Please enquire   |
|    | Does not apply, since the entire switchgear needs to be evaluated.                             |
|    | Does not apply, since the entire switchgear needs to be evaluated.                             |
|    | Meets the product standard's requirements.   |
|    | Does not apply, since the entire switchgear needs to be evaluated.                             |
|    | Meets the product standard's requirements.   |
|    | Does not apply, since the entire switchgear needs to be evaluated.                             |
|    | Does not apply, since the entire switchgear needs to be evaluated.                             |
|    | Is the panel builder's responsibility.   |
|    | Is the panel builder's responsibility.   |
|    |  |
|    | Is the panel builder's responsibility.   |
|    | Is the panel builder's responsibility.   |
|    | Is the panel builder's responsibility.   |
|    | Not applicable.  |
|    | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
|    | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
|    | The device meets the requirements, provided the information in the instruction                 |
|    |  |

#### **Technical data ETIM 6.0**

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss8.1-27-37-12-13 [AKF031011])


| [AKFU31U11])                          |    |         |
|---------------------------------------|----|---------|
| Number of switch positions            |    | 2       |
| Type of control element               |    | Toggle  |
| Suitable for illumination             |    | Yes     |
| Colour control element                |    | Black   |
| Colour indicator light cap            |    | Blue    |
| Construction type lens                |    | Round   |
| Hole diameter                         | mm | 22.5    |
| Width opening                         | mm | 0       |
| Height meter opening                  | mm | 0       |
| Switching function latching           |    | Yes     |
| Spring-return Spring-return           |    | No      |
| Degree of protection (IP), front side |    | IP66    |
| With front ring                       |    | Yes     |
| Material front ring                   |    | Plastic |
| Colour front ring                     |    | -       |
|                                       |    |         |


## **Approvals**

| • •                     |  |
|-------------------------|--|
| Product Standards       | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
| UL File No.             | E29184   |
| UL Category Control No. | NKCR   |
| CSA File No.            | 012528   |
| CSA Class No.           | 3211-03  |

UL/CSA Type 3R, 4X, 12, 13

## **Dimensions**





## **Additional product information (links)**

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan

ftp://ftp.moeller.net/DOCUMENTATION/AWA\_INSTRUCTIONS/IL04716002Z2015\_02.pdf