



PLS6-C25-MW 242683

Part no.

Article no.

Powering Business Worldwide"

Similar to illustration

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed.	Design verification as per IEC/EN 61439			
Heat dissipation per pole, current-dependent Pade West 0 Equipment heat dissipation, current-dependent Pade West 3 Struic heat dissipation, current-dependent Pade West 0 Heat dissipation, current-dependent Pade West 0 Operating ambient temperature min. Correction affect temperature min. 70 75 Operating ambient temperature max. To a 55% reduction of current carrying capacity. 76 75 10.2.2 Consolt on resistance Mest the product standard's requirements. 76 76 10.2.3 Verification of resistance of insulating materials to aboremal heat 76 76 76 10.2.3 Verification of resistance of insulating materials to aboremal heat 76 76 76 10.2.3 Verification of resistance of insulating materials to aboremal heat 76 76 76 10.2.3 Verification of resistance of insulating materials to aboremal heat 76 76 76 10.2.5 Verification of resistance of insulating materials to aboremal heat 76 76 76 10.2.5 Verification of resistance of insulating materials to aboremal heat 76 <td>Technical data for design verification</td> <td></td> <td></td> <td></td>	Technical data for design verification			
Equipment heat dissipation, current-dependent Pead W 3 Static heat dissipation, current-dependent Pead W 0 Heat dissipation capacity Pead W 0 Operating ambient temperature min. Pead PC 25 Operating ambient temperature max. Pead PC 35 ID2 Strength of materials and parts Pead Pea	Rated operational current for specified heat dissipation	I _n	А	25
Stuic heat dissipation, non-current-dependent Pen W Heat dissipation capacity Peiss W 0 Operating ambient temperature min. PC S S Operating ambient temperature max. PC 75 S EVEN 61458 design verification Function Function Function Function 10.2.2 Consolin resistance Function Function Mests the product standard's requirements. Function 10.2.2 Verification of festinate of insulating materials to normal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to abnormal heat function of resistance of insulating materials to a	Heat dissipation per pole, current-dependent	P _{vid}	W	0
Person Person V Operating ambient temperature min. °C 25 Operating ambient temperature max. °C 75 Inter, per +1°C, results in a 0.5% reduction of current carrying capacity Inter, per +1°C, results in a 0.5% reduction of current carrying capacity ID2.5 trength of metorials and parts Inter, per +1°C, results in a 0.5% reduction of current carrying capacity ID2.3 Lordification of thermal stability of enclosures Meets the product standard's requirements. ID2.3 Lordification of resistance of insultating materials to abnormal heat Meets the product standard's requirements. ID2.3 Lordification of resistance of insultating materials to abnormal heat Meets the product standard's requirements. ID2.3 Lordification of resistance of insultating materials to abnormal heat Meets the product standard's requirements. ID2.3 Lordification of resistance of insultating materials to abnormal heat Meets the product standard's requirements. ID2.3 Lordification of resistance of insultating materials to abnormal heat Meets the product standard's requirements. ID2.5 Lindip Meets the product standard's requirements. Meets the product standard's requirements. ID2.5 Lindip Meets the product standard's requirements. Meets the product standard's requirements. I	Equipment heat dissipation, current-dependent	P _{vid}	W	3
Operating ambient temperature min. C 25 Operating ambient temperature max. C 75 Itel/EN 61438 design verification Image, per +1 °C, results in a 0.5% reduction of current carrying capacity. 10.2 Strength of materials and parts Meets the product standard's requirements. 10.2.2 Corrasion resistance Meets the product standard's requirements. 10.2.3.1 Varification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.2 Varification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.3.2 Varification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 10.2.5 Lifting Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the enrire switchgear needs to be evaluated. 10.2.5 Mechanical impact Does not apply, since the enrire switchgear needs to be evaluated. 10.2.5 Protection of ASSEMBUES Does not apply, since the enrire switchgear needs to be evaluated. 10.3 Degree of protectins of switching devices and components Does not apply, since the enrire switchgear needs to be evaluated. 10.3 Internal electrical circuits and connections Empale builder's responsibility. 10.3 I	Static heat dissipation, non-current-dependent	P _{vs}	W	0
Operating ambient temperature max. Image: Construct on temperature max. 75 Incert, per +1 *C, results in a 0.5% reduction of current carrying capacity Incert, per +1 *C, results in a 0.5% reduction of current carrying capacity ID2.5 trength of materials and parts Meets the product standard's requirements. Incert, per +1 *C, results in a 0.5% reduction of current carrying capacity ID2.2 Corrosion resistance Insultation of temistance of insulating materials to abnormal heat Meets the product standard's requirements. ID2.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. ID2.3 Uverification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. ID2.5 Uring Does not apply, since the entire switchgear needs to be evaluated. ID2.5 Uring Does not apply, since the entire switchgear needs to be evaluated. ID3.0 begree of protection of ASSEMBLIES Dees not apply, since the entire switchgear needs to be evaluated. ID3.0 begree of protection of visching dovices and components Dees not apply, since the entire switchgear needs to be evaluated. ID3.0 begree of protection of visching dovices and components Dees not apply, since the entire switchgear needs to be evaluated. ID3.0 begree of protection of visching dovices and components Image: per visching visching vi	Heat dissipation capacity	P _{diss}	W	0
Internation Internation ID2 Strength of materials and parts Meets the product standard's requirements. ID22 Corrosion resistance Meets the product standard's requirements. ID23 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. ID23 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. ID23 Verification of resistance of insulating materials to abormal heat Meets the product standard's requirements. ID23 Verification of resistance of insulating materials to abormal heat Meets the product standard's requirements. ID23 Verification of resistance of insulating materials to abormal heat Meets the product standard's requirements. ID23 Degree of protection of ASSEMBLES Does not apply, since the entire switchgear needs to be evaluated. ID24 Interviews and components Meets the product standard's requirements. ID3 Degree of protection of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. ID25 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. ID3 Interpretating devices and components IS the panel builder's responsibility. ID3 Interpretative rise IS the panel builder's responsibility.	Operating ambient temperature min.		°C	-25
IEUCEN 61439 design verification Image: Construct of the state	Operating ambient temperature max.		°C	75
102.2 Strength of materials and parts Meets the product standard's requirements. 102.2.2 Corrosion resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.5 Protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 104.0 Earnances and creepage distances Meets the product standard's requirements. 105.1 Fortection of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 105.2 Reside of external conductors Is the panel builder's responsibility. 108 Connections for external conductors Is the panel builder's responsibility. 109 Insulation properties Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's re				linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.3.2 Verification of resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Prover-frequency electric strength Is the panel builder's responsibility. 10.9 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Theretion against electric strength Is the panel builder	IEC/EN 61439 design verification			
10.2.3.1 Verification of thermal stability of enclosuresMeets the product standard's requirements.10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effectsMeets the product standard's requirements.10.2.3.4 Resistance to ultra-violat (UV) radiationMeets the product standard's requirements.10.2.4 Resistance to ultra-violat (UV) radiationMeets the product standard's requirements.10.2.5 LiftingDees not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3.0 Degree of protection of ASSEMBLIESDees not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDees not apply, since the entire switchgear needs to be evaluated.10.8 Connections for external conductorsDees not apply, since the entire switchgear needs to be evaluated.10.9.1 Nermal electrical circuits and connectionsDees not apply, since the entire switchgear needs to be evaluated.10.9.2 Power-frequency electric strengthEs the panel builder's responsibility.10.9.3 Ingulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseThe panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear mus observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear mus observed.10.13 Mechanical functionThe device me	10.2 Strength of materials and parts			
102.3.2 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.3.3 Verification of resistance of insulating materials to abnormal heat Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.5 Logree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility. 10.9.2 Electromagnetic compatibility. Is the panel bui	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Dees not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Dees not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric stock Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Normal electric licicuits and components Dees not apply, since the entire switchgear needs to be evaluated. 10.8 Incorporation of switching devices and components Dees not apply, since the entire switchgear needs to be evaluated. 10.9 Insulation properties Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Themperature rise Is the panel builder's responsibility. 10.9.1 Themperature rise Is the panel builder's responsibility. 10.11 Shor	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.1 Protection against electric strength Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.1 Temperature rise Is the panel builder's responsibility.	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Subtast of voltageIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.1 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear mus observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear mus observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear mus observed. </td <td></td> <td></td> <td></td> <td>Meets the product standard's requirements.</td>				Meets the product standard's requirements.
10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Power-frequency electric strengthIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.1 Therpare triesIs the panel builder's responsibility.10.9.1 Therpare triesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.1 Therpare triesIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe dev	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 InscriptionsMeets the product standard's requirements.10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.1 Dy.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIESDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.1 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseThe panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear mus observed.10.13 Mechanical functionThe device meets the requirements, provide the information in the instruction	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9 Insulation propertiesIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionThe device meets the requirements, provide the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties Image: Constraint of the second se	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must observed.10.13 Mechanical functionImage: Compatibility for the temperature in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton with provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function The device meets the requirements, provide the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must observed. 10.13 Mechanical function Image: Compatibility of the switchgear must observed.	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.12 Electromagnetic compatibility observed. 10.13 Mechanical function Image: Compatibility of the system of the sys	10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 6.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss8.1-27-14-19-01 [AAB905011])

Release characteristic

Number of poles (total)		1
Number of protected poles		1
Nominal rated current	А	25
Nominal rated voltage	V	230
Rated short-circuit breaking capacity Icn EN 60898 at 230 V	kA	6
Rated short-circuit breaking capacity Icn EN 60898 at 400 V	kA	6
Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V	kA	0
Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V	kA	0
Voltage type		AC
Current limiting class		3
Frequency	Hz	50 - 60
Concurrently switching N-neutral		No
Suitable for flush-mounted installation		No
Over voltage category		3
Pollution degree		2
Width in number of modular spacings		1
Built-in depth	mm	70.5
Additional equipment possible		Yes
Degree of protection (IP)		IP20